

कार्यालय महाप्रबन्धक  
जलकल विभाग-नगर निगम  
PRAYAGRAJ JAL KAL VIBHAG LABORATORY

CHEMICAL ANALYSIS OF WATER

Test Report

पत्र संख्या 1391/म.प्र.ज.क.ले.प.प.22  
दिनांक 18-01-2022

Sl. No.

- 1 Source of Sample water Sample, Ewing christian public school Cnr  
2 Date of Sampling 15-1-2022 Received 712 Muthiganj Prayagraj  
3 Date of Analysis 15-1-2022

Physico Chemical Parameter	BIS Limit IS 10500: 2012		Result of Test
	Requirement (Desirable Limit) (mg/l)	Permissible limit in the absence alternate source (mg/l)	
4 Total Dissolved solids	500	2000	413
Hardness Total as CaCO <sub>3</sub>	200	600	240
5 (a) Temporary as CaCO <sub>3</sub>	NS	NS	120
(b) Permanent as CaCO <sub>3</sub>	NS	NS	120
6 Chlorine as-Chlorides Cl	250	1000	100
7 Total Alkalinity as CaCO <sub>3</sub>	200	600	50
8 Nitrites as NO <sub>2</sub>	NS	NS	Nil
9 Iron as Fe	0.3	No relaxation	0.1
10 Fluoride as F	1.0	1.5	0.6
11 Colour Hazen Unit	5	1.5	colourless
12 Taste		Agreeable	satisfactory
13 Odour		Agreeable	odourless
14 pH Value	6.5 to 8.5	No relaxation	6.8
15 Conductivity as $\mu$ hos at 20°C	NS	NS	590
16 Turbidity NTU	1	5	1
17 Free Residual Chlorine	0.2	NS	Nil

NS= Not Specified

Potable

Remark

Chemist

AE(HO)

Ex.Engg. (HQ)

आंध्रशाखा अभियन्ता (मु०)

Dated: जलकल विभाग, नगर निगम

प्रयागराज

End No

J.K

Copy forwarded for information to:

- 1 The addl. Director, State Health Institute, Sector-C, Chetan Vihar, Aliganj, Lucknow, U.P.
- 2 Chief Medical Officer, Prayagraj.
- 3 Mukhya Nagar Swasthya Adhikari, Nagar Nigam, Prayagraj.
- 4 Nagar Ayukta, Nagar Nigam, Prayagraj.
- 5 The superintending Engineer (R&D) office of Addl. Chief Engineer (PPR&D), U.P. Jal Nigam, 6 Rana Pratap Marg, Lucknow.
- 6 Chairman, Jal Kal Vibhag/ Mayour, Nagar Nigam, Prayagraj.


Ex.Engg. (HQ)

# ALLAHABAD JAL KAL VIBHAG LABORATORY

Result of the Bacteriological examination of the Water taken from Water Sample  
 Name & Designation of the person collecting the sample Mr. Sunjeet Loh. & Primsipal.

Date & time of collection	Date of receipt and inoculation	Source of Sample	Colony Count on agar plate in 1 ml.		Presumptive coliform count	Probable No. of coliform organism in 100 ml. of original water	Free residual chlorine mg/l	Remarks	
			At 37°C in 48 hours	At room temperature in 72 hours					Quantity of water put up in each tube/No. of tubes put up
15-1-2022	15-1-2022	Water Sample	—	—	0	0	0	0	Nil Excess

*Ewing christiam*  
*Public school campus*  
*712 Muthi gong*  
*Rayagray*

Chemist 

~~Chemist~~  AELHO

Ex. Engineer (HQ)  
 अधिशाषी अभियन्ता (मुख्य)  
 जलकल विभाग, नगर निगम  
 प्रयागराज

S-111

End. No. D/

/ J.J.K/

Dated : Allahabad

20

Copy Forwarded for information to :

1. The Joint Director, State Health Institute, U.P. Sector-C, Chetan Vihar, Aliganj, Lucknow.
2. The Superintending Engineer (R & D) Office of Addl. Chief Engineer (PPR & D),  
U.P. Jal Nigam 6, Rana Pratap Marg, Lucknow.
3. Senior Nagar Swasthya Adhikari, Nagar Nigam, Allahabad.
4. Chairman Jal Kai Vibhag / Hon'ble Mahapour, Nagar Nigam, Allahabad.
5. City Commissioner, Nagar Nigam, Allahabad.
6. C.M.O., Allahabad

**Executive Engineer (HQ)**


कार्यालय नगर स्वास्थ्य अधिकारी नगर निगम, प्रयागराज

पत्रांक डी0: /23 /6-स्वा0वि0/2022 दिनांक 02-2-2022

अनापत्ति प्रमाण-पत्र

प्रबन्धक, इविंग क्रिश्चियन पब्लिक स्कूल, 712 मुट्ठीगंज, प्रयागराज द्वारा प्रस्तुत प्रार्थना-पत्र दिनांक 13.01.2022 के क्रम में इविंग क्रिश्चियन पब्लिक स्कूल का निरीक्षण क्षेत्रीय सफाई एवं खाद्य निरीक्षक द्वारा किया गया। क्षेत्रीय सफाई एवं खाद्य निरीक्षक की रिपोर्ट दिनांक 28.01.2022 के अनुसार स्कूल में बने शौचालय-मूत्रालय की साफ-सफाई व्यवस्था की व्यवस्था संतोषजनक पायी गयी।

अतः स्वास्थ्य के दृष्टिगत से विद्यालय का संचालन किये जाने में स्वास्थ्य विभाग नगर, निगम, प्रयागराज को कोई आपत्ति नहीं है।

  
नगर स्वास्थ्य अधिकारी /  
पर्यावरण स्वास्थ्य अधिकारी  
नगर निगम, प्रयागराज